

Prüfinstitut:
I.F.I., Institut für
Industrieaerodynamik GmbH

Anschrift:
Welkenrather Straße 120
D-52074 Aachen

Prüfungsleitung:
Dipl.-Ing. B. Konrath

Institutsleitung:
Dipl.-Ing. B. Konrath
Dipl.-Ing. R.-D. Lieb

Type testing of a VAV- system according to DIN EN 14 175-6:2006



I.F.I. Institut für
Industrieaerodynamik GmbH
Institut an der
Fachhochschule Aachen

Certificate No. 1/TVRK-200/07/07

VAV-System:

Designation : **TROX TVRK/200/TRA/FH**
Type : TROX Labcontrol TCU II
Diameter : 200 mm
Range VAV : 285–1458 m³/h
Range press. : $\Delta p_{\min} = 20 \text{ Pa}$ (285 m³/h), 70 Pa (1458 m³/h)
 $\Delta p_{\max} = 1000 \text{ Pa}$ (285 m³/h, 1458 m³/h)
Manufacturer: Trox GmbH
Address : Heinrich-Trox-Platz
D-47504 Neukirchen-Vluyn

Max. nominal extract air volume rate : 1458 m³/h
Min. nominal extract air volume rate : 285 m³/h
Tested extract air volume rates : 1458-700-285 m³/h
Date of testing : 10.07.-24.07.2007

The variabel air volume system **TROX TVRK/200/TRA/FH** has been subjected to a type examination test for variabel air volume fume cupboards according to DIN EN 14 175-6 of August 2006. The air flow rate characteristics, the dynamic control modes and the setpoint values of the VAV-systems have been tested according to the requirements of DIN EN 14175-6:2006 at the above mentioned extract air volume flow rates.

The tested variabel air volume system **TROX TVRK/200/TRA/FH** is in accordance with DIN EN 14175-6:2006.

The detailed results and test conditions of the type examination test of the variable air volume systems are given in „Test report No. 1/TVRK-200/07/07“.

Date of issue: 23.08.2007

Head of test station:

Dipl.-Ing. B. Konrath

Test station:

I.F.I. Institut für
Industrieaerodynamik GmbH
Institut an der
Fachhochschule Aachen
Welkenrather Str. 120
D-52074 Aachen



Responsible test engineer:

M. Winklehner